

18-4-2023 to 18-4-2026



**GOVERNMENT OF TRIPURA
DIRECTORATE OF FIRE & EMERGENCY
SERVICES
AGARTALA : TRIPURA**



Phone: 0381-232-6451

Email: dg.fire-tr@gov.in

website: www.fireservice.tripura.gov.in

No: FSCTFES/2023/00038

Dated: 18/04/2023

Sub: FIRE SAFETY CERTIFICATE

Certified that the building or premises as mentioned below have complied with the fire prevention and fire safety requirements in accordance with the conditions laid down in the relevant portions of Part-IV of the latest National Building Code and the Tripura Building Rules and that the building/ premises is fit for occupancy class Institutional for a period of 3 (three) year(s) in accordance with renewal from time to time.

Name of the Applicant:-	Sahaya Lourdu Raj			
Name of Owner with Plot details:-	S. No.	Owner Name and Address		
	1.	লীজ দং হলিক্রস স্কুল পক্ষে ফা. আজি পল কুমারঘাট ১লা জানুয়ারী ২০০৮ ইং সন হইতে ৫০ বৎসরের জন্য লীজ ইউ.আই.ডি.নং :- xxxxxxxxxxxxxx		
		S. No.	Plot No	Total Area
		1.	3444	0.35
		2.	3445	0.02
		3.	3446	0.03
		4.	3447	0.07
		5.	3448	1.54
		6.	3449	0.4
		7.	3450	0.16
		8.	3451	0.38
		9.	3459	0.35
		10.	3465	0.33
		11.	3466	0.16
		12.	3467	0.04
	13.	3468	1.48	
	14.	3469	0.08	
			Classification	
			লুঙ্গা	
			টিনা	

			টিনা	
			টিনা	
			লুঙ্গা	
			লুঙ্গা	
			লুঙ্গা	

			নাল	
Name of the Property/ Organization/ Commercial establishment	Holy Cross School, Pabiacherra, Kumarghat			
Address of the Building/ Premises:-	Kumarghat Habitation, Sukanta Nagar Gram Panchayat, Kumarghat Block, Post Office Kumarghat S.O - 799264, Unakoti District, Tripura.			

**Director,
Fire & Emergency Services,
Or Authorized Signatory
Tripura : Agartala**

This certificate will expire on 18/04/2026

Conditions for the Validity of Fire Safety Certificate (NOC).

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.

2. There should not be any change of Trade for which this License has been issued.

Digitally signed by Debjani Deb Sarkar
Date: 2023.04.18 12:41:22 +05:30

3. Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.

4. Water reservoir should always be kept full up to brim.

5. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.

6. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

The Fire NOC is issued for only the portion of mentioned area that is being occupied by "Holy Cross School" (RCC [G+2] storied building). Applicants Name- Shri Sahaya Lourdu Raj (on behalf of trust). No way shall it be applicable for the other portions.